

**CLIENT:** **SMOOTH-ON**  
5600 Lower Macungie Road  
Macungie, PA 18062

<b>Test Report No: TJ4503-Rev.1</b>	<b>Date: February 10, 2017</b>
-------------------------------------	--------------------------------

**SAMPLE ID:** The client identified the following test material as “**Habitat Cast N Coat**”

**SAMPLING DETAIL:** Test samples were submitted to the laboratory directly by the client. No special sampling conditions or sample preparation were observed by QAI.

**DATE OF RECEIPT:** Samples were received at QAI facilities on January 1, 2017

**TESTING PERIOD:** February 9, 2017

**AUTHORIZATION:** Signed work order 17SP020303 Ed. 2 signed by Rahul Amin

**TEST REQUESTED:** Perform standard flame spread and smoke density developed classification tests on the sample supplied by the Client in accordance with ASTM Designation E84-15, "Standard Method of Test for Surface Burning Characteristics of Building Materials". The foregoing test procedure is comparable to UL 723, ANSI/NFPA No. 255, and UBC No. 8-1.

<b>TEST RESULTS:</b>	<b><u>Flame Spread</u></b>	<b><u>Smoke Developed</u></b>
	25	165

**CLASSIFICATION:** The material results in a class “A” rating. Detailed test results are presented in the subsequent pages of this report.

**Prepared By**



Daniel Barnett  
Project Engineer

**Signed for and on behalf of  
QAI Laboratories, Inc.**



J. Brian McDonald  
Operations Manager